


Test Verification of Conformity

Verification Number: 240221012GZU-VOC001

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it <them>.

Applicant Name & Address:	EG4 Electronics LLC 1130 Como Street South, Sulphur Springs, TX 75482
Product Description:	LiFePO ₄ battery
Ratings & Principle Characteristics:	See Appendix: Test Verification of Conformity
Models/Type References:	WM-48-280-1-IN-LL-00, WM-48I280-LL-00, WM-48-280-2-IN-LL-00, WM-48-280-3-IN-LL-00, WM-48-280-4-IN-LL-00, WM-48-280-5-IN-LL-00, WM-48-280-6-IN-LL-00 EG4 ELECTRONICS (EG4 ELECTRONICS)
Brand Names:	
Specification<s>/Standards:	ANSI/CAN/UL 9540A:2019 Test Method for Evaluating Thermal Runaway Fire Propagation in Battery Energy Storage Systems Unit level test (clause 9.1-9.8)
Verification Issuing Office Name & Address:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch. Room 101/301/401/102/202/302/402/502/602/702/802, No. 7-2, Caipin Road, Huangpu District, Guangzhou, Guangdong, China
Date of Tests:	01 February 2024 to 02 February 2024
Test Report Number(s):	240221012GZU-001

Additional information in Appendix.



Signature

Name: Jason Fu
Position: Supervisor
Date: 26 March 2024

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 240221012GZU-VOC001.

Ratings & Principle Characteristics:

Model	WM-48-280-1-IN-LL-00, WM-48I280-LL-00	WM-48-280-2-IN-LL-00	WM-48-280-3-IN-LL-00
Rated capacity (Ah):	280 Ah	560 Ah	840Ah
Rated energy (kWh):	14.336 kWh	28.672 kWh	43.008 kWh
Nominal voltage (V):	51.2Vdc	51.2Vdc	51.2Vdc
Weight(kg):	127±0.5 kg	2*127±0.5 kg	3*127±0.5 kg
Module series and/or parallel configuration:	1S1P	1S2P	1S3P
Standard charge method:			
Charge current (A):	70 A	140 A	210A
End of charge voltage (V):	56.0V		
Standard discharge method:			
Discharge current (A):	70 A	140 A	210A
End of discharge voltage (V):	43.2 V		
Rest time between charge and discharge	30min		

Jason Fu

Signature

Name: Jason Fu

Position: Supervisor

Date: 26 March 2024


This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 240221012GZU-VOC001.

Ratings & Principle Characteristics:

Model	WM-48-280-4-IN-LL-00	WM-48-280-5-IN-LL-00	WM-48-280-6-IN-LL-00
Rated capacity (Ah):	1120 Ah	1400 Ah	1680 Ah
Rated energy (kWh):	57.344 kWh	71.680 kWh	86.016 kWh
Nominal voltage (V):	51.2Vdc	51.2Vdc	51.2Vdc
Weight(kg):	4*127±0.5 kg	5*127±0.5 kg	6*127±0.5 kg
Module series and/or parallel configuration:	1S4P	1S5P	1S6P
Standard charge method:			
Charge current (A):	280 A	350 A	420 A
End of charge voltage (V):	56.0V		
Standard discharge method:			
Discharge current (A):	280 A	350 A	420 A
End of discharge voltage (V):	43.2 V		
Rest time between charge and discharge	30min		



Signature

Name: Jason Fu

Position: Supervisor

Date: 26 March 2024

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.