

EG₄ ELECTRONICS

51.2V 100ah Lifepower4 V2 Firmware Changelog

| Date: | Changelog: |
|------------|--|
| 09-25-2024 | Firmware: <ul style="list-style-type: none">• RS485: Z02T04- Corrected the EG4 RS485 inverter protocol for the following inverters: EG4 3000EHV EG4 6000EX EG4 6500EX |
| 10-29-2024 | Firmware: <ul style="list-style-type: none">• RS485: Z02T05- Corrected the EG4 Monitor Portal communication between a 51.2V 100ah Lifepower4 V2 and 51.2V 100ah Lifepower4 V1 reporting a 51% SOC that is only inaccurate on the EG4 Monitor Portal. |
| 04-14-2025 | Firmware: <ul style="list-style-type: none">• RS232: S02T24- Corrected the Cycle count logic to: Cumulative discharge 80% (80 ah) = +1 Cycle count |