


# Test Verification of Conformity

Verification Number: 250820046GZU-VOC001

On the basis of the tests undertaken, the sample<s> of the below product has been tested by an accredited 3rd party laboratory in accordance to the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it <them>.

Applicant Name & Address:	EG4 Electronics LLC 1130 Como Street South, Sulphur Springs, TX 75482, USA
Product Description:	Rechargeable Li-ion Battery
Ratings & Principle Characteristics:	See Appendix: Test Verification of Conformity
Models/Type References:	WM48314AW, WM-48-314-1-AW-, WM-48-314-2-AW-, WM-48-314-3-AW-, WM-48-314-4-AW-, WM-48-314-5-AW-, WM-48-314-6-AW-, may be followed by 00 to 99
Brand Names:	<b>EG4 ELECTRONICS</b> (EG4 ELECTRONICS)
Specification<s>/Standards:	ANSI/CAN/UL 9540A:2025 Test Method for Evaluating Thermal Runaway Fire Propagation in Battery Energy Storage Systems Unit level test (clause 9.1-9.8)
Verification Issuing Office Name & Address:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch. Room101/301/401/102/202/302/402/502/602/702/802, No. 7-2, Caipin Road, Huangpu District, Guangzhou, Guangdong, China
Date of Tests:	20 September 2025 – 23 September 2025
Test Report Number(s):	250820046GZC-001. 22 December 2025
Additional information in Appendix.	



Signature

Name: Jason Fu

Position: Manager

Date: 22 December 2025

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 250820046GZU-VOC001.

Ratings & Principle Characteristics:

Model:	WM48314AW, WM-48-314-1- AW-, may be followed by 00 to 99	WM-48-314-2- AW-, may be followed by 00 to 99	WM-48-314-3- AW-, may be followed by 00 to 99
Rated capacity (Ah):	314 Ah	628 Ah	942 Ah
Rated energy (kWh):	16 kWh	32 kWh	48 kWh
Nominal voltage (V):	51.2 V		
Weight(kg):	140(±0.5) kg	280(±1) kg	420(±1.5) kg
Module series and/or parallel configuration:	1S1P	1S2P	1S3P
Total number of cells:	16	32	48
Standard charge method:			
Charge current (A):	157 A	314 A	471 A
End of charge voltage (V):	57 V		
Standard discharge method:			
Discharge current (A):	157 A	314A	471 A
End of discharge voltage (V):	44.8 V		
Rest time between charge and discharge	30 min		

Jason Fu

Signature

Name: Jason Fu

Position: Manager

Date: 22 December 2025

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 250820046GZU-VOC001.

Ratings & Principle Characteristics:

Model:	WM-48-314-4-AW-, may be followed by 00 to 99	WM-48-314-5-AW-, may be followed by 00 to 99	WM-48-314-6-AW-, may be followed by 00 to 99
Rated capacity (Ah):	1256 Ah	1570 Ah	1884 Ah
Rated energy (kWh):	64 kWh	80 kWh	96 kWh
Nominal voltage (V):	51.2 V		
Weight(kg):	560(±2) kg	700(±2.5) kg	840(±3) kg
Module series and/or parallel configuration:	1S4P	1S5P	1S6P
Total number of cells:	64	80	96
Standard charge method:			
Charge current (A):	628 A	785 A	942 A
End of charge voltage (V):	57 V		
Standard discharge method:			
Discharge current (A):	628 A	785 A	942 A
End of discharge voltage (V):	44.8 V		
Rest time between charge and discharge	30 min		

*Jason Fu*

**Signature**

**Name: Jason Fu**

**Position: Manager**

**Date: 22 December 2025**

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.